



**DANA HILLS HIGH SCHOOL & TESORO HIGH SCHOOL TRACK RESURFACING
Bid No. 2324-06**

**ADDENDUM NO. 1
February 5, 2024**

Please note the following additions, corrections, clarifications, and revisions, to the above-referenced Bid. The additions, corrections, clarifications, and revisions are as follows:

CLARIFICATIONS AND ADDITIONAL INFORMATION

- 1. Attached are the responses to all received RFI:**
 - a. RFI No. 1 - Sportbuild

CAPISTRANO UNIFIED SCHOOL DISTRICT

Josh Readman
Supervisor, Purchasing

Pre-Bid RFI No. 1

PRE-BID CLARIFICATION FORM (For Contractor's Use)			
PROJECT NAME:	BID NO. 2324-06 DHHS & THS Track Resurfacing (Installation Only)		
PROJECT NUMBER:	231 and 232		
TO:	Daniel Clem, Vice President, TELACU & Josh Readman, Supervisor, Purchasing	EMAIL:	dclem@telacu.com & jdreadman@capousd.org

DATE:	2/1/24		
FROM:	Sportbuild, David Snell	EMAIL:	dave@sportbuild.com
DOCUMENT/DIVISION NUMBER:		DRAWING NUMBER:	

<p>REQUESTED CLARIFICATION:</p> <p>We noticed this requires a (A) license. Does a B license override the A license? Or vice versa? We also noticed that in your renderings you have the track's exchange zones at 20 meters. Im assuming you are going to want to go with the new standard which is 30 meters. This results in a slight price fluctuation. My understanding is that the "Rekortan" materials are mandatory? The reason we ask is we prefer not to use them anymore and this could be the deciding factor in whether or not we take on this project.</p>
--

<p>RESPONSE TO CLARIFICATION:</p> <p>Bid docs call for a Class B license, not A.</p> <p>30m is the correct track exchange zone distance, please update from 20 to 30.</p> <p>The Rekortan material has already been purchased by the District via a CMAS agreement, this bid is for INSTALLATION ONLY.</p>

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.