



**HAROLD AMBUEHL ELEMENTARY SCHOOL HVAC PROJECT  
Bid No. 2324-08**

**ADDENDUM NO. 2  
March 18, 2024**

Please note the following additions, corrections, clarifications, and revisions, to the above-referenced Bid. The additions, corrections, clarifications, and revisions are as follows:

**CLARIFICATIONS AND ADDITIONAL INFORMATION**

- 1. Attached are the responses to all received RFI:**
  - a. RFI No. 1 – Pacific West Industries, Inc.

**CAPISTRANO UNIFIED SCHOOL DISTRICT**

Josh Readman  
Supervisor, Purchasing

# Pre-Bid RFI No. 1

<b>PRE-BID CLARIFICATION FORM</b> (For Contractor's Use)			
PROJECT NAME:	BID NO. 2324-08 Ambuehl Elementary School HVAC Project		
PROJECT NUMBER:	207		
TO:	Daniel Clem & Josh Readman	EMAIL:	<a href="mailto:dclem@telacu.com">dclem@telacu.com</a> & <a href="mailto:jdreadman@capousd.org">jdreadman@capousd.org</a>

DATE:	3/14/24		
FROM:	Devin Johnson Pacific West Industries, Inc	EMAIL:	Devin@pacwestac.com
DOCUMENT/DIVISION NUMBER:	Div. 23	DRAWING NUMBER:	M0.1 thru M3.1

## REQUESTED CLARIFICATION:

During the job walk, it was discussed that lvu controls would be added to this site. The new equipment appears to include factory SystemVu controllers. Please advise on the following controls inquiries:

1. Are the existing thermostats and/or controls to be replaced or reconnected to the new units?
2. What is currently controlling the existing units?
3. If new controls are required, will they be owner or contractor provided?
4. Is there an existing EMS system the units will need to be tied into?

## RESPONSE TO CLARIFICATION:

1. Existing thermostats to be replaced and connected to the new units.
2. Thermostats are currently controlling the units.
3. Contractor to supply t-stats
4. There is not a current EMS system.

Attach additional numbered sheets as necessary; however, only one (1) request shall be contained on each submitted form.